



Type Test Report				Cert. No.							
Customer:				M-file ref.:							
				Date of Issue 03/22/2005							
Customer ref.:				Type: M2QA160L4A							
				Serial no.: 0AD127-151/04-1							
Rating: 3~Motor				Product Code 3GQA 162 501							
Insul.cl.F S1 IP55 137 kg		V		Hz	kW	r/min	A	cos φ	IA/IN	TE[s]	
		690		Y	50	15	1460	16.22	0.86		
		400		D	50	15	1460	27.97	0.86		
		660		Y	50	15	1452	16.57	0.88		
		380		D	50	15	1452	28.78	0.88		
		415		D	50	15	1461	27.28	0.85		
440		D	60	17.3	1752	28.17	0.88				
Resistance Line Pole Ambient 25 °C 4 0.5249 Ω				Insulation resistance R > 200 Mohm				Overload test			
				High-voltage test 2380 V 60 s							
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]		
No Load		400	D 50	8.97	0.4215		1500				
Rated load (cold)		400	D 50	28.5	16.611	15	1461				
Rated load (stab.)	98.56	400	D 50	27.79	16.644	15	1454.1	0.8645	90.12		
146% rated load	143.33	400	D 50	45.66	25.465	21.9	1426.8	0.805	86		
Shortcircuit	226.69	400	D 50	193			0				
		100	D 50	34.75	2.603		0				
Temperature rise at amb.temp. 30 °C Stator winding Pole (K) Method 4 66.7 1				Temperature Pole °C Method Ambient 4 30 2 Frame 4 58 2				Measurement method 1 Resistance 2 Thermometer 3 Thermocouples			
Manufactured and tested in accordance with rules of IEC 60034-1.											
On behalf of customer											
On behalf of manufacturer				Date of test 08/09/2004							
Tested by ABB Shanghai Motors Co., Ltd											

Computer print-out valid without signature

ABB Motors

ABB Shanghai Motors Co., Ltd
88 Tianning Road ,Minhang Economic

200245 Shanghai China

Phone: +86 21 54723133
Fax: +86 21 54725009

and Technological Development Zone